



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER

PUBLIC NOTICE

**IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
FAILURE TO MONITOR**

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Weatherly Borough

Our water system violated one or more drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 10/21/25 we failed to report a sample result within 30 days as required and during 12/24/25 we submitted an incorrect date for a sample result.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, the required sampling frequency, how many samples we took, when samples should have been taken, and the date on which corrective action samples were (or will be) taken.

| Contaminant | Required sampling frequency | Number of samples taken | When all samples should have been taken | When samples were or will be taken |
|-----------------------------|-----------------------------|-------------------------|---|------------------------------------|
| Revised Total Coliform Rule | Monthly | 3 | 10/22/2025 | 10/22/2025 |
| Chlorine | Weekly | 3 | 12/24/2025 | 12/24/2025 |

What happened? What was done? When will it be resolved?

10/21/25 a sample reading was completed due to a previous positive result for Coliform but not reported to DEP within 30 days; corrected on 1/14/2026. 12/24/25 three sample readings were collected but reported improperly with the wrong date of 12/30/25 resulting in a violation; corrected on 2/4/2026.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Weatherly Borough at 570-427-8640.

Certified by:

Signature: Tracy Grover

Date: 3/31/26

Print Name and Title: Tracy Grover, Borough Manager



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF SAFE DRINKING WATER

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: mail/newsletter

PWS ID#: 3130015

Date distributed: 4/1/2026